

9 December 2013

 Cnr Hill Road & Pondage Link,
 Homebush Bay,
 NSW 21276

 EPL 4560:
<http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEO Licence.aspx?DOCID=29520&SYSUID=1&LICID=4560>

Data testing on the MTOH (Point A Main Thermal Oil Heater) and for Quarterly Odour test from OCF (Point D, "Central Thermal Oxidiser/Dryer Plant Stack (air))

Transpacific Technical Services tested 13 and 14 November 2013.

Results Received 30 November 2013:

Outlet	Test 1	Test 2
MTOH Nitrogen oxides	0.062 g/m ³	Not applicable
MTOH Carbon monoxide	<2.5 mg/m ³	Not applicable
MTOH particulates	20 mg/m ³	Not Applicable
MTOH carbon dioxide	2.2 %	Not Applicable
MTOH Odour	2,900 oum ³ /s	Not applicable
OCF	6,100 oum ³ /s	3,200 oum ³ /s

Transpacific Technical Services site plan.

