



EPL No:	10251
Entity Name	Cleanaway Industrial Solutions Pty Ltd
Site:	10-12 Waynote Place, Unanderra NSW
Monitoring Frequency:	Quarterly
Link to NSW EPA Register:	Click Here

Sample ID	Published Date	Obtained Date	Sampled Date	Sampled Parameters									Comment/s
				pH	Suspended Solids (SS)	Arsenic	Cadmium	Lead	Zinc	Hexavalent Chromium	Oil & Grease	Biochemical Oxygen Demand	
				pH unit	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	
Assessment Criteria				-	-	-	-	-	-	-	-	-	
EPA ID No.2 - First Flush Discharge	22/07/2021	21/07/2021	21/07/2021	7.72	28.00	0.0020	<0.0001	0.0030	0.0200	0.001	<5	3.00	
EPA ID No.2 - First Flush Discharge	5/07/2021	2/07/2021	25/06/2021	7.52	128.00	0.0020	<0.0001	0.0070	0.0320	<0.01	<5	14.00	System cleaned out and controls inspected with drain wardens to be replaced.
EPA ID No.2 - First Flush Discharge	29/03/2021	26/03/2021	18/03/2021	7.79	110.00	0.0030	0.0001	0.0120	0.0800	<0.01	<5	<2	System cleaned out and controls inspected.
EPA ID No.2 - First Flush Discharge	13/01/2021	12/01/2021	4/01/2021	7.30	18.00	0.0020	<0.0001	0.0020	0.0230	<0.01	<5	3.00	
EPA ID No.2 - First Flush Discharge		4/08/2020	27/07/2020	8.51	145.00	<0.001	<0.0001	0.0080	0.0880	<0.01	<5	<2	
Please note, prior to the above samples being taken Cleanaway has been collecting and transporting first flush stormwater to the Charcoal Close, Unanderra Facility (EPL No.10771).													