



EPL No:	10251
Entity Name:	Cleanaway Industrial Solutions Pty Ltd
Site:	10-12 Waynote Place, Unanderra NSW
Monitoring Frequency:	Quarterly
Link to NSW EPA Register:	<a href="#">Click Here</a>

**Discharge & Monitoring Point 2**

Wet weather discharge, Discharge point on western boundary, marked "A" on Stormwater Construction Drawing dated 18/08/2003 provided to the EPA with licence variation request dated 30/5/2006

Pollutant	Unit of measure	EPL Limit	No. of samples required per reporting period*	No. of samples collected and analysed to date*	Sample 1	Exceedance (Yes / No)	Sample 2	Exceedance (Yes / No)	Sample 3	Exceedance (Yes / No)	Sample 4	Exceedance (Yes / No)	Lowest sample value*	Mean of sample*	Highest sample value*		
Arsenic	milligrams per litre	-	4	3	<0.001	No	<0.001	No	<0.001	No	No discharge has occurred from this monitoring point.	N/A	0.0000	0.0000	0.0000		
BOD	milligrams per litre	-	4	3	2.0000	No	<2	No	4.0000	No		N/A	0.0000	2.0000	4.0000		
Cadmium	milligrams per litre	-	4	3	<0.0001	No	<0.0001	No	<0.0001	No		N/A	0.0000	0.0000	0.0000		
Chromium (hexavalent)	milligrams per litre	-	4	3	<0.01	No	<0.01	No	<0.01	No		N/A	0.0000	0.0000	0.0000		
Lead	milligrams per litre	-	4	3	<0.001	No	0.0020	No	0.0010	No		N/A	0.0000	0.0010	0.0020		
Oil and Grease	Visible	-	4	3	<5	No	<5	No	<5	No		N/A	0.0000	0.0000	0.0000		
pH	-	-	4	3	7.6500	No	7.9900	No	7.4500	No		N/A	7.4500	7.6967	7.9900		
Total suspended solids	milligrams per litre	50	4	3	18.0000	No	18.0000	No	14.0000	No		N/A	14.0000	16.6667	18.0000		
Zinc	milligrams per litre	-	4	3	0.0440	No	0.0220	No	0.0250	No		N/A	0.0220	0.0303	0.0440		
			21/02/2023	21/02/2023	1/02/2023				21/02/2023	21/02/2023		14/02/2023				20/04/2023	20/04/2023
			Published Date	Report Date	Sample Date				Published Date	Report Date	Sample Date				Published Date	Report Date	Sample Date

**Discharge & Monitoring Point 3**

Wet weather discharge, Western site boundary adjacent to old liquid treatment plant

Pollutant	Unit of measure	EPL Limit	No. of samples required per reporting period*	No. of samples collected and analysed to date*	Sample 1	Exceedance (Yes / No)	Sample 2	Exceedance (Yes / No)	Sample 3	Exceedance (Yes / No)	Sample 4	Exceedance (Yes / No)	Lowest sample value*	Mean of sample*	Highest sample value*		
Arsenic	milligrams per litre	-	4	0	No discharge has occurred from this monitoring point.	N/A	No discharge has occurred from this monitoring point.	N/A	No discharge has occurred from this monitoring point.	N/A	No discharge has occurred from this monitoring point.	N/A	N/A	N/A	N/A		
BOD	milligrams per litre	-	4	0		N/A		N/A		N/A		N/A					
Cadmium	milligrams per litre	-	4	0		N/A		N/A		N/A		N/A					
Chromium (hexavalent)	milligrams per litre	-	4	0		N/A		N/A		N/A		N/A					
Lead	milligrams per litre	-	4	0		N/A		N/A		N/A		N/A					
Oil and Grease	Visible	-	4	0		N/A		N/A		N/A		N/A					
pH	-	-	4	0		N/A		N/A		N/A		N/A					
Total suspended solids	milligrams per litre	50	4	0		N/A		N/A		N/A		N/A					
Zinc	milligrams per litre	-	4	0		N/A		N/A		N/A		N/A					
			N/A	N/A		N/A						N/A	N/A	N/A			
			Published Date	Report Date	Sample Date				Published Date	Report Date	Sample Date				Published Date	Report Date	Sample Date