



Pollutant Monitoring Results - Wet Weather Discharge

Licensee Name:	SUEZ Australia	Environmental Protection Licence Number:	4068	Facility Address:	
Period:	January 2021 - March 2021	A copy of the full licence can be found on the POEO Public Register http://www.epa.nsw.gov.au/prpoeoapp/			

1725 Elizabeth Drive,
KEMPS CREEK, NSW, 2178

Disclaimer - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the requirements issued in writing by the Environment Protection Authority. To the best of SUEZ's knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior consent from SUEZ. For more details on publication of pollution monitoring data refer to the NSW EPA Website www.epa.nsw.gov.au

Date Final Monitoring Obtained	Sampling Point	No. of times measured during reporting period	Pollutant	Monitoring Frequency Required by licence	Min Value	Mean Value	Median Value	Max Value	Unit	If Applicable Pollutant limit as per licence	Exceedance (Y/N) or NA	Comments
Special Frequency 1 means the collection of samples on the first day of the discharge, and at least once every calendar month during continued discharge events thereafter.												
30 March 2021	13 - ADP002	2	Conductivity	Special Frequency 1	660	1330	1330	2000	µS/cm	N/A	N/A	
30 March 2021	13 - ADP002	2	Biological Oxygen Demand	Special Frequency 1	5	6.15	6.15	7.3	mg/L	N/A	N/A	
30 March 2021	13 - ADP002	2	Nitrogen (Ammonia)	Special Frequency 1	0.52	0.575	0.575	0.63	mg/L	0.9	N/A	
30 March 2021	13 - ADP002	2	Total Organic Carbon	Special Frequency 1	22	136	136	250	mg/L	N/A	N/A	
30 March 2021	13 - ADP002	2	Total Suspended Solids	Special Frequency 1	45	107.5	107.5	170	mg/L	50	N/A	
30 March 2021	15 - ADP003	2	Conductivity	Special Frequency 1	320	650	650	980	µS/cm	N/A	N/A	
30 March 2021	15 - ADP003	2	Biological Oxygen Demand	Special Frequency 1	5	7.5	7.5	10	mg/L	N/A	N/A	
30 March 2021	15 - ADP003	2	Nitrogen (Ammonia)	Special Frequency 1	0.06	0.075	0.075	0.09	mg/L	0.9	N	
30 March 2021	15 - ADP003	2	Total Organic Carbon	Special Frequency 1	9	119.5	119.5	230	mg/L	N/A	N/A	
30 March 2021	15 - ADP003	2	Total Suspended Solids	Special Frequency 1	23	25.5	25.5	28	mg/L	50	N	
30 March 2021	34 - S19 overflow	2	Conductivity	Special Frequency 1	1700	2300	2300	2900	µS/cm	N/A	N/A	
30 March 2021	34 - S19 overflow	2	Biological Oxygen Demand	Special Frequency 1	5	7.5	7.5	10	mg/L	N/A	N/A	
30 March 2021	34 - S19 overflow	2	Nitrogen (Ammonia)	Special Frequency 1	0.33	0.53	0.53	0.73	mg/L	0.9	N	
30 March 2021	34 - S19 overflow	2	Total Organic Carbon	Special Frequency 1	15	72.5	72.5	130	mg/L	N/A	N/A	
30 March 2021	34 - S19 overflow	2	Total Suspended Solids	Special Frequency 1	65	68.5	68.5	72	mg/L	50	N	
30 March 2021	35 - ADP001	1	Conductivity	Special Frequency 1	1500	1500	1500	1500	µS/cm	N/A	N/A	
30 March 2021	35 - ADP001	1	Biological Oxygen Demand	Special Frequency 1	10	10	10	10	mg/L	N/A	N/A	
30 March 2021	35 - ADP001	1	Nitrogen (Ammonia)	Special Frequency 1	2.9	2.9	2.9	2.9	mg/L	0.9	N	
30 March 2021	35 - ADP001	1	Total Organic Carbon	Special Frequency 1	20	20	20	20	mg/L	N/A	N/A	
30 March 2021	35 - ADP001	1	Total Suspended Solids	Special Frequency 1	380	380	380	380	mg/L	50	N	