



Pollutant Monitoring Results - Wet Weather Discharge

License Name:	SUEZ Australia	Environmental Protection Licence Number:	4068	Facility Address:	
Period:	Oct 2021 - Dec 2021	A copy of the full licence can be found on the POEO Public Register http://www.epa.nsw.gov.au/poecorp/			

Disclaimer - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the requirements issued in writing by the Environment Protection Authority. To the best of SUEZ's knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior consent from SUEZ. For more details on publication of pollution monitoring data refer to the NSW EPA Website www.epa.nsw.gov.au

Date Final Monitoring Obtained	Sampling Point	No. of times measured during reporting period	Pollutant	Monitoring Frequency Required by licence	Min Value	Mean Value	Median Value	Max Value	Unit	If Applicable Pollutant limit as per licence	Exceedance (Y/N) or NA	Comments
Special Frequency 1 means the collection of samples on the first day of the discharge, and at least once every calendar month during continued discharge events thereafter.												
12/11/2021	13 - ADP002	1	Conductivity	Special Frequency 1	1700	1700	1700	1700	µS/cm	N/A	N/A	
12/11/2021	13 - ADP002	1	Biological Oxygen Demand	Special Frequency 1	<5	<5	<5	<5	mg/L	N/A	N/A	
12/11/2021	13 - ADP002	1	Nitrogen (Ammonia)	Special Frequency 1	0.14	0.14	0.14	0.14	mg/L	0.9	N/A	
12/11/2021	13 - ADP002	1	Total Organic Carbon	Special Frequency 1	11	11	11	11	mg/L	N/A	N/A	
12/11/2021	13 - ADP002	1	Total Suspended Solids	Special Frequency 1	40	40	40	40	mg/L	50	N/A	



Pollutant Monitoring Results - Wet Weather Discharge

Licensee Name:	SUEZ Australia	Environmental Protection Licence Number:	4068	Facility Address:	
Period:	Oct 2021 - Dec 2021	A copy of the full licence can be found on the POEO Public Register http://www.epa.nsw.gov.au/poecorp/			

Disclaimer - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the requirements issued in writing by the Environment Protection Authority. To the best of SUEZ's knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior consent from SUEZ. For more details on publication of pollution monitoring data refer to the NSW EPA Website www.epa.nsw.gov.au

Date Final Monitoring Obtained	Sampling Point	No. of times measured during reporting period	Pollutant	Monitoring Frequency Required by licence	Min Value	Mean Value	Median Value	Max Value	Unit	If Applicable Pollutant limit as per licence	Exceedance (Y/N) or NA	Comments
12/11/2021	15 - ADP003	1	Conductivity	Special Frequency 1	770	770	770	770	µS/cm	N/A	N/A	
12/11/2021	15 - ADP003	1	Biological Oxygen Demand	Special Frequency 1	<5	<5	<5	<5	mg/L	N/A	N/A	
12/11/2021	15 - ADP003	1	Nitrogen (Ammonia)	Special Frequency 1	0.31	0.31	0.31	0.31	mg/L	0.9	N	
12/11/2021	15 - ADP003	1	Total Organic Carbon	Special Frequency 1	7.1	7.1	7.1	7.1	mg/L	N/A	N/A	
12/11/2021	15 - ADP003	1	Total Suspended Solids	Special Frequency 1	39	39	39	39	mg/L	50	N	



Pollutant Monitoring Results - Wet Weather Discharge

Licensee Name:	SUEZ Australia	Environmental Protection Licence Number:	4068	Facility Address:	
Period:	Oct 2021 - Dec 2021	A copy of the full licence can be found on the POEO Public Register http://www.epa.nsw.gov.au/poecorp/			

Disclaimer - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the requirements issued in writing by the Environment Protection Authority. To the best of SUEZ's knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior consent from SUEZ. For more details on publication of pollution monitoring data refer to the NSW EPA Website www.epa.nsw.gov.au

Date Final Monitoring Obtained	Sampling Point	No. of times measured during reporting period	Pollutant	Monitoring Frequency Required by licence	Min Value	Mean Value	Median Value	Max Value	Unit	If Applicable Pollutant limit as per licence	Exceedance (Y/N) or NA	Comments
12/11/2021	34 - S19 overflow	1	Conductivity	Special Frequency 1	3000	3000	3000	3000	µS/cm	N/A	N/A	
12/11/2021	34 - S19 overflow	1	Biological Oxygen Demand	Special Frequency 1	5.4	5.4	5.4	5.4	mg/L	N/A	N/A	
12/11/2021	34 - S19 overflow	1	Nitrogen (Ammonia)	Special Frequency 1	0.25	0.25	0.25	0.25	mg/L	0.9	N	
12/11/2021	34 - S19 overflow	1	Total Organic Carbon	Special Frequency 1	5.9	5.9	5.9	5.9	mg/L	N/A	N/A	
12/11/2021	34 - S19 overflow	1	Total Suspended Solids	Special Frequency 1	14	14	14	14	mg/L	50	N	