



Pollutant Monitoring Results - Wet Weather Discharge

Licensee Name: Cleanaway

Environment Protection Licence Number: 4068

Facility Address: 1725 Elizabeth Drive,
KEMPS CREEK, NSW, 2178

Period: January 2024 - March 2024

A copy of the full licence can be found on the POEO Public Register
<http://www.epa.nsw.gov.au/prpoeoapp/>

Disclaimer - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the requirements issued in writing by the Environment Protection Authority. To the best of Cleanaway's knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior consent from Cleanaway. For more details on publication of pollution monitoring data refer to the NSW EPA Website www.epa.nsw.gov.au

Date Final Monitoring Obtained	Date Monitored	Sampling Point	No. of times measured during reporting period	Pollutant	Monitoring Frequency Required by licence	Min Value	Mean Value	Median Value	Max Value	Unit	If Applicable Pollutant limit as per licence	Exceedance (Y/N) or NA	Comments
23/02/2024	15/02/2024	35 - ADP001	1	Conductivity	Special Frequency 1	2160	2160	2160	2160	µS/cm	N/A	N/A	
23/02/2024	15/02/2024	35 - ADP001	1	Biological Oxygen Demand	Special Frequency 1	5	5	5	5	mg/L	N/A	N/A	
23/02/2024	15/02/2024	35 - ADP001	1	Nitrogen (Ammonia)	Special Frequency 1	<0.01	<0.01	<0.01	<0.01	mg/L	0.9	N	
23/02/2024	15/02/2024	35 - ADP001	1	Total Organic Carbon	Special Frequency 1	10	10	10	10	mg/L	N/A	N/A	
23/02/2024	15/02/2024	35 - ADP001	1	Total Suspended Solids	Special Frequency 1	152	152	152	152	mg/L	50	Y	Part 12.5 of the licence states: Exceedance of a quality limit specified in this licence for the discharge of TSS from EPA identification numbers, Points 13, 15, 34 and 35 is permitted if the discharges occur solely as a result of rainfall at the premises exceeding a total of 48 millimetres over any consecutive five day period. Dam level was low and it was being emptied for repair, pumped discharge was stopped once the sample was taken.
-	-	13 - ADP002	1	Conductivity	Special Frequency 1	N/A	N/A	N/A	N/A	µS/cm	N/A	N/A	
-	-	13 - ADP002	1	Biological Oxygen Demand	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	N/A	N/A	
-	-	13 - ADP002	1	Nitrogen (Ammonia)	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	0.9	N	
-	-	13 - ADP002	1	Total Organic Carbon	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	N/A	N/A	
-	-	13 - ADP002	1	Total Suspended Solids	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	50	N	Part 12.5 of the licence states: Exceedance of a quality limit specified in this licence for the discharge of TSS from EPA identification numbers, Points 13, 15, 34 and 35 is permitted if the discharges occur solely as a result of rainfall at the premises exceeding a total of 48 millimetres over any consecutive five day period.
-	-	15 - ADP003	1	Conductivity	Special Frequency 1	N/A	N/A	N/A	N/A	µS/cm	N/A	N/A	
-	-	15 - ADP003	1	Biological Oxygen Demand	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	N/A	N/A	
-	-	15 - ADP003	1	Nitrogen (Ammonia)	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	0.9	N	
-	-	15 - ADP003	1	Total Organic Carbon	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	N/A	N/A	
-	-	15 - ADP003	1	Total Suspended Solids	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	50	N	Part 12.5 of the licence states: Exceedance of a quality limit specified in this licence for the discharge of TSS from EPA identification numbers, Points 13, 15, 34 and 35 is permitted if the discharges occur solely as a result of rainfall at the premises exceeding a total of 48 millimetres over any consecutive five day period.
-	-	34 - S19 overflow	1	Conductivity	Special Frequency 1	N/A	N/A	N/A	N/A	µS/cm	N/A	N/A	
-	-	34 - S19 overflow	1	Biological Oxygen Demand	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	N/A	N/A	
-	-	34 - S19 overflow	1	Nitrogen (Ammonia)	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	0.9	N	
-	-	34 - S19 overflow	1	Total Organic Carbon	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	N/A	N/A	
-	-	34 - S19 overflow	1	Total Suspended Solids	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	50	N	Part 12.5 of the licence states: Exceedance of a quality limit specified in this licence for the discharge of TSS from EPA identification numbers, Points 13, 15, 34 and 35 is permitted if the discharges occur solely as a result of rainfall at the premises exceeding a total of 48 millimetres over any consecutive five day period.



Pollutant Monitoring Results - Wet Weather Discharge

Licensee Name: Cleanaway

Environment Protection Licence Number: 4068

Facility Address: 1725 Elizabeth Drive,
KEMPS CREEK, NSW, 2178

Period: January 2024 - March 2024

A copy of the full licence can be found on the POEO Public Register
<http://www.epa.nsw.gov.au/prpoeoapp/>

Disclaimer - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the requirements issued in writing by the Environment Protection Authority. To the best of Cleanaway's knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior consent from Cleanaway. For more details on publication of pollution monitoring data refer to the NSW EPA Website www.epa.nsw.gov.au

Date Final Monitoring Obtained	Date Monitored	Sampling Point	No. of times measured during reporting period	Pollutant	Monitoring Frequency Required by licence	Min Value	Mean Value	Median Value	Max Value	Unit	If Applicable Pollutant limit as per licence	Exceedance (Y/N) or NA	Comments
27/02/2024	20/02/2024	35 - ADP001	1	Conductivity	Special Frequency 1	1800	1800	1800	1800	µS/cm	N/A	N/A	
27/02/2024	20/02/2024	35 - ADP001	1	Biological Oxygen Demand	Special Frequency 1	2	2	2	2	mg/L	N/A	N/A	
27/02/2024	20/02/2024	35 - ADP001	1	Nitrogen (Ammonia)	Special Frequency 1	0.07	0.07	0.07	0.07	mg/L	0.9	N	
27/02/2024	20/02/2024	35 - ADP001	1	Total Organic Carbon	Special Frequency 1	5	5	5	5	mg/L	N/A	N/A	
27/02/2024	20/02/2024	35 - ADP001	1	Total Suspended Solids	Special Frequency 1	14	14	14	14	mg/L	50	N	Part L2.5 of the licence states: Exceedance of a quality limit specified in this licence for the discharge of TSS from EPA Identification numbers, Points 13, 15, 34 and 35 is permitted if the discharges occur solely as a result of rainfall at the premises exceeding a total of 48 millimetres over any consecutive five day period.
-	-	13 - ADP002	1	Conductivity	Special Frequency 1	N/A	N/A	N/A	N/A	µS/cm	N/A	N/A	
-	-	13 - ADP002	1	Biological Oxygen Demand	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	N/A	N/A	
-	-	13 - ADP002	1	Nitrogen (Ammonia)	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	0.9	N	
-	-	13 - ADP002	1	Total Organic Carbon	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	N/A	N/A	
-	-	13 - ADP002	1	Total Suspended Solids	Special Frequency 1	N/A	N/A	N/A	N/A	mg/L	50	N	Part L2.5 of the licence states: Exceedance of a quality limit specified in this licence for the discharge of TSS from EPA Identification numbers, Points 13, 15, 34 and 35 is permitted if the discharges occur solely as a result of rainfall at the premises exceeding a total of 48 millimetres over any consecutive five day period.
27/02/2024	20/02/2024	15 - ADP003	1	Conductivity	Special Frequency 1	1780	1780	1780	1780	µS/cm	N/A	N/A	
27/02/2024	20/02/2024	15 - ADP003	1	Biological Oxygen Demand	Special Frequency 1	<2	<2	<2	<2	mg/L	N/A	N/A	
27/02/2024	20/02/2024	15 - ADP003	1	Nitrogen (Ammonia)	Special Frequency 1	0.11	0.11	0.11	0.11	mg/L	0.9	N	
27/02/2024	20/02/2024	15 - ADP003	1	Total Organic Carbon	Special Frequency 1	6	6	6	6	mg/L	N/A	N/A	
27/02/2024	20/02/2024	15 - ADP003	1	Total Suspended Solids	Special Frequency 1	9	9	9	9	mg/L	50	N	Part L2.5 of the licence states: Exceedance of a quality limit specified in this licence for the discharge of TSS from EPA Identification numbers, Points 13, 15, 34 and 35 is permitted if the discharges occur solely as a result of rainfall at the premises exceeding a total of 48 millimetres over any consecutive five day period.
27/02/2024	20/02/2024	34 - S19 overflow	1	Conductivity	Special Frequency 1	1770	1770	1770	1770	µS/cm	N/A	N/A	
27/02/2024	20/02/2024	34 - S19 overflow	1	Biological Oxygen Demand	Special Frequency 1	2	2	2	2	mg/L	N/A	N/A	
27/02/2024	20/02/2024	34 - S19 overflow	1	Nitrogen (Ammonia)	Special Frequency 1	0.11	0.11	0.11	0.11	mg/L	0.9	N	
27/02/2024	20/02/2024	34 - S19 overflow	1	Total Organic Carbon	Special Frequency 1	10	10	10	10	mg/L	N/A	N/A	
27/02/2024	20/02/2024	34 - S19 overflow	1	Total Suspended Solids	Special Frequency 1	12	12	12	12	mg/L	50	N	Part L2.5 of the licence states: Exceedance of a quality limit specified in this licence for the discharge of TSS from EPA Identification numbers, Points 13, 15, 34 and 35 is permitted if the discharges occur solely as a result of rainfall at the premises exceeding a total of 48 millimetres over any consecutive five day period.