



Pollutant Monitoring Results - Wet Weather Discharge

EPL No:	4068
Entity Name:	Elizabeth Drive Landfill
Site:	1725 Elizabeth Drive, KEMPS CREEK, NSW, 2178
Monitoring Frequency:	Quarterly
Link to NSW EPA Register:	Click Here

Disclaimer - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the requirements issued in writing by the Environment Protection Authority. To the best of Cleanaway's knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior consent from Cleanaway. For more details on publication of pollution monitoring data refer to the NSW EPA Website www.epa.nsw.gov.au

		Ammonia	Total Suspended Solids	Conductivity	Total Organic Carbon	Biological Oxygen Demand	Rainfall over any consecutive 5 day period	Comments
		mg/L	mg/L	µS/cm	mg/L	mg/L	mm	
Pollutant Limit		0.9	50	n/a	n/a	n/a		
ADP002 (EPA ID 13)	9/04/2024	0.78	1020	569	7	5	184.6	
	No. of samples required	Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1		
	No. of samples collected and analysed	1	1	1	1	1		
	Min	0.78	1020	569	7	5		
	Max	0.78	1020	569	7	5		
	Average	0.78	1020	569	7	5		
ADP003 (EPA ID 15)	20/02/2024	0.11	9	1780	6	<2	42	
	8/04/2024	0.13	198	687	5	2	199.4	
	6/05/2024	2	56	948	41	45	28.2	
	13/05/2024	1.6	88	1073	15	13	30.8	
	3/06/2024	1.6	51	1093	10	5	31.4	
	17/06/2024	1.8	45	1072	-	-	7.6	Administrative error - TOC and BOD not analysed
	4/07/2024	1.6	<10	1104	8	<2	24.2	
	15/08/2024	1.3	<10	1218	8	4	21.8	
	No. of samples required	Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1		
	No. of samples collected and analysed	8	8	8	7	7		
	Min	0.11	9.00	687.00	5.00	2.00		
Max	2.00	198.00	1780.00	41.00	45.00			
Average	1.27	74.50	1121.88	13.29	13.80			
S19 Overflow (EPA ID 36)	20/02/2024	0.11	12	1770	10	2	42	
	5/04/2024	0.08	60	1990	8	<2	61.6	
	19/04/2024	0.04	26	1920	9	4	2.2	
	6/05/2024	22*	220	2660	196	229	28	Ammonia result considered anomolous - resample on the 14/5/2024 was below the criteria
	14/05/2024	<0.8	58	2055	-	-	40	Administrative error - TOC and BOD samples not submitted to the lab
	3/06/2024	<0.8	<10	1996	8	24	31.4	
	17/06/2024	<0.8	<10	1963	9	2	7.6	
	4/07/2024	<0.8	<10	1961	8	<2.1	24.2	
	15/08/2024	<0.8	<10	2270	17	4	21.8	
	30/09/2024	<0.8	<10	2760	9	3	44.2	
	18/10/2024	<0.8	16	3040	12	5	19.2	
	25/10/2024	<0.8	<10	2900	10	<2	3.6	
	18/11/2024	<0.8	<10	3260	10	3	14.8	
	29/11/2024	<0.8	16	3650	16	4	20	
	9/12/2024	<0.8	13	3000	13	2	21	
	No. of samples required	Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1		
No. of samples collected and analysed	9	9	9	8	8			
Min	0.04	12.00	1770.00	8.00	2.00			
Max	0.11	220.00	3650.00	196.00	229.00			
Average	0.08	52.63	2479.67	23.93	25.64			
	15/02/2024	<0.01	152	2160	10	5	4.2	

		Ammonia	Total Suspended Solids	Conductivity	Total Organic Carbon	Biological Oxygen Demand	Rainfall over any consecutive 5 day period	Comments
		mg/L	mg/L	µS/cm	mg/L	mg/L	mm	
Pollutant Limit		0.9	50	n/a	n/a	n/a		
ADP001 (EPA ID 35)	20/02/2024	0.07	14	1800	5	2	42	
	5/04/2024	0.14	338	2100	6	<2	61.6	
	19/04/2024	15.2	34	1610	58	59	2.2	
	6/05/2024	2	318	579	2	5	28	
	14/05/2024	7.5	<10	1955	-	-	40	Administrative error - TOC and BOD samples not submitted to the lab
	3/06/2024	6.3	167	2180	18	5	31.4	
	17/06/2024	5.4	56	2140	12	3	7.6	
	4/07/2024	3.8	36	2147	9	<2.9	24.2	
	No. of samples required	Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1		
	No. of samples collected and analysed	9	9	9	8	8		
	Min	0.07	14.00	579.00	2.00	2.00		
Max	15.20	338.00	2180.00	58.00	59.00			
Average	5.05	139.38	1852.33	15.00	13.17			

Comments:

- Exceedence of a quality limit specified in this licence for the discharge of TSS from EPA identification numbers, Points 13, 15, 34 and 35 is permitted if the discharges occur solely as a result of rainfall at the premises exceeding a total of 48 millimetres over any consecutive five day period.

- Special Frequency 1 as stipulated by EPL 4068 Condition M2.5 means the collection of samples:

a) on the first day of the discharge from Points 13, 15, 34, and 35 and at least once every calendar month during continued discharge events thereafter.

*** - Result considered anomolous.