

Pollutant Monitoring Results - Wet Weather Discharge



EPL No:	4068
Entity Name:	Elizabeth Drive Landfill
Site:	1725 Elizabeth Drive, KEMPS CREEK, NSW, 2178
Monitoring Frequency:	Quarterly
Link to NSW EPA Register:	Click Here

Disclaimer - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the requirements issued in writing by the Environment Protection Authority. To the best of Cleanaway's knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior consent from Cleanaway. For more details on publication of pollution monitoring data refer to the NSW EPA Website www.epa.nsw.gov.au

				Ammonia	Total Suspended Solids	Conductivity	Total Organic Carbon	Biological Oxygen Demand	Rainfall over any consecutive 5 day period	Comments
				mg/L	mg/L	µS/cm	mg/L	mg/L	mm	
Pollutant Limit				0.9	50	n/a	n/a	n/a		
	Date Monitoring Data Uploaded	Date Monitoring Data Obtained	Monitoring Date							
ADP002 (EPA ID 13)	n/a	n/a	n/a							
	No. of samples required			Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1		
	No. of samples collected and analysed			0	0	0	0	0		
	Min			0	0	0	0	0		
	Max			0	0	0	0	0		
	Average			#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!		
ADP003 (EPA ID 15)		24/02/2025	16/01/2025	1.4	<10	1819	11	4	33.4	
	No. of samples required			Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1		
	No. of samples collected and analysed			1	1	1	1	1		
	Min			1.40	0.00	1819.00	11.00	4.00		
	Max			1.40	0.00	1819.00	11.00	4.00		
	Average			1.40	#DIV/0!	1819.00	11.00	4.00		
S19 Overflow (EPA ID 36)		4/02/2025	31/01/2025	<0.8	<10	2470	14	4	2.8	
		21/02/2025	17/02/2025	<0.8	11	2070	12	3	30.8	
	No. of samples required			Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1		
	No. of samples collected and analysed			2	2	2	2	2		
	Min			<0.8	11.00	2070.00	12.00	3.00		
	Max			<0.8	11.00	2470.00	14.00	4.00		
Average			<0.8	11.00	2270.00	13.00	3.50			
ADP001 (EPA ID 35)		22/01/2025	21/01/2025	3.8	12	1402	-	-	15.4	
	No. of samples required			Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1	Special Frequency 1		
	No. of samples collected and analysed			1	1	1	0	8		
	Min			3.80	12.00	1402.00	0.00	0.00		
	Max			3.80	12.00	1402.00	0.00	0.00		
	Average			3.80	12.00	1402.00	#DIV/0!	#DIV/0!		

Comments:
- Exceedence of a quality limit specified in this licence for the discharge of TSS from EPA identification numbers, Points 13, 15, 34 and 35 is permitted if the discharges occur solely as a result of rainfall at the premises exceeding a total of 48 millimetres over any consecutive five day period.

- Special Frequency 1 as stipulated by EPL 4068 Condition M2.5 means the collection of samples:
a) on the first day of the discharge from Points 13, 15, 34, and 35 and at least once every calendar month during continued discharge events thereafter.

"*" - Result considered anomalous.
"- " - Analysis not conducted for this pollutant
"n/a" - no discharge events for this monitoring point